



CB TEST CERTIFICATE

Ref. Certificate No.

NL-9848

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: KEMA Quality B.V.

Registration date: 2005-11-14

Product: MAGNETIC CONTACTOR WITH THERMAL OVERLOAD RELAY AND ACCESSORIES

Applicant: LS INDUSTRIAL SYSTEMS CO., LTD. 84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul Korea, Republic Of

Manufacturer: LS INDUSTRIAL SYSTEMS CO., LTD. 84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul Korea, Republic Of

Factory: LS INDUSTRIAL SYSTEMS CO., LTD. Cheongju Plant 1, Songjeong-dong Heungdeok-gu Cheongju-si Chungchengbuk-do Korea, Republic Of

Rating and principal characteristics: General product details:
 Ue/Uj :
 - 1000 V (for contactors and auxiliaries)
 - 690 V (for thermal overload relays)
 Uimp:
 - 8 kV (contactors and auxiliaries)
 - 6 kV (overload relays)
 See Annex for detailed product specifications.

Trade mark (if any): LS

Model/Type reference: MC-9, -12, -18, -25, -32, -35, -40, -50, -63, -65, -75, -85, -95 / MT-32, -63, -95 versions /2H, /3H, /3K, /3D (TOR) / UA-1 (auxiliary contact) / UR-02 (Interlock unit)

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-4-1(ed.2);am1
60947-5-1(ed.2);am1;am2

Test Report Ref. No: 2084466.50-57

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2005-11-14